



D2E Guidance

Lone Working
Arrangements for
Façade Access
Equipment
2016





Report title Guidance on Lone Working Arrangements for
Façade Access Equipment

Client All

Reference SAE-Guidance-1-D2E/27/06/16

Version	Prepared by	Date	Checked by	Date	Comment
1	Mike Fairweather	27/06/16	Amy Dacres- Dixon	22/07/16	Grammar
2					
3					
4					
5					



Contents Page

1	Introduction	1
1.1	D2E's Position	1
2	Risk Assessment for Lone Working	1
2.1	The Hazards	1
2.2	Decide who can be harmed and why	2
2.3	Evaluate the risks and decide on control measures.....	2
2.4	Record your findings and implement them.....	3
2.5	Monitor and update them as necessary	3
	Disclaimer:	3



1 Introduction

The aim of this document is to provide some guidance to assist with possible actions and planning for lone working arrangements – operation, testing, inspection, maintenance, and thorough examination of façade access equipment.

HASAW 1974 – it shall be the duty of every employer to ensure, so far as is reasonably practicable, the health, safety, and welfare at work of all his employees.

Duty holders have a responsibility for ensuring that the work is properly planned, appropriately supervised, and carried out in as safe a way as reasonably practicable (WAHR:2005, regulation 4).

NB. HSE Guidance note – INDG73 Working alone – gives further guidance

1.1 D2E's Position

Employers need to ensure that their employees remain healthy and safe whilst at work; this includes working in and around buildings and in remote or isolated areas. The basis for developing any procedure is through completion of a thorough risk assessment and then applying the findings to develop suitable safe working practices.

2 Risk Assessment for Lone Working

The procedure for carrying out risk assessments is no different from the normal work place risk assessment process:

1. Identify the hazards
2. Decide who can be harmed and why
3. Evaluate the risks and decide on precautions
4. Record your findings and implement them
5. Monitor and update them as necessary

2.1 The Hazards

(Something with the potential to cause harm).

Listed below are a sample of hazards applicable to Façade Access working situations. They may be exacerbated by the working area and fact that a person is alone and perhaps not in the immediate vicinity of aide and assistance.

e.g. Working at Height

- Fall risk due to location of equipment
- Sail effect of lifting large panels to expose machinery
- Climbing in and out of cradle to operate limit switches and controls
- Rigging of equipment

- Accessing the work area, from ladders, mobile elevated work platforms, hatches etc.
- Rescue from façade access equipment due to breakdown or sudden illness
- Operation of equipment emergency lowering maybe a two-person operation
- Sudden illness rendering the worker unable to summon help
- Rescue – from harness due to fall arrest scenario
- Weather (High wind, rain, ice, snow, hot sunny weather)
- Electric shocks
- Entrapment in moving parts
- Faulty equipment
- Fire
- Manual handling heavy or unwieldy loads – large cover panels on equipment, weights for load testing
- Equipment rigging is often a two-person operation
- Poor or lack of training
- Pregnant or young workers
- Remoteness or isolation
- Working in confined spaces
- Working over or near water

2.2 Decide who can be harmed and why

In this case it is only the lone worker

2.3 Evaluate the risks and decide on control measures

In consultation with employees, and their representatives, decide on the level of risk posed by the situation.

This will determine whether or not extra controls are required, or whether or not the job can be undertaken safely by a single person.

Depending on the results you may need to insist that the high risk work is completed by more than one operative.

Examples of control measures may include but are not limited to the following:

- Access to communications
- Automatic warning devices
- First aid equipment and training
- Further specialist training



- Introducing a 'buddy system'
- Lifting equipment
- Out of office recording procedures
- Periodic supervisory checks
- Personal alarms
- Safe working practices
- Security staff

2.4 Record your findings and implement them

- Complete, document and record the risk assessment, which should be simple and focused on the control measures.

2.5 Monitor and update them as necessary

- Few workplaces stay the same. Sooner or later changes will occur
- New workers or working practices/procedures that could lead to new hazards
- Review what you are doing on an on-going basis, and check you risk assessment again asking the following questions:
 - Have there been any significant changes?
 - Are there improvements you still need to make?
 - Have your workers spotted a problem?
 - Have you learnt anything from accidents or near misses?

Disclaimer: D2E wish to clarify that nothing contained in this document changes, modifies, supersedes or in any way seeks to make other recommendations to the information and/or regulations published by the recommended industry specialists.



Contact Information

7 Denbigh Mews, Westminster
London SW1V 2HQ

+44 (0) 207 233 9355
info@d2e.com

d2e.com

-  Vertical Transport
-  Façade Access Management
-  Design
-  Contract Administration
-  Modernisation
-  Servicing & Maintenance
-  Project Management
-  Surveys

Our accreditations

